



GEORGE I. REITZ & SONS, INC.

Brookville, PA (814)849-2308

E Pittsburgh, PA (412)824-9976



EMERGENCY PROCEDURES UNDERGROUND STORAGE TANK SYSTEMS Class C Operators for Unmanned Facilities (Class C Operator May Be 2 HOURS Away)

Class C Operator. A Class C operator is the first line of response to events indicating emergency conditions. This person is responsible for responding to alarms or other indications of emergencies caused by spills or releases from underground storage tank systems and equipment failures. A Class C operator must be trained before beginning their duties. There must be at least one Class C operator on duty at all times when the facility is in operation.

Posted Procedures for Unmanned Facilities	
CONTACT PHONE NUMBER THAT WILL REACH CLASS C OPERATOR OR OWNER:	
<hr/>	
EMERGENCY PHONE NUMBERS:	
POLICE: _____	FIRE DEPARTMENT: _____
HAZARDOUS RESPONSE: _____	EMERGENCY: 911
WHAT TO DO WHEN THERE IS AN ALARM FROM THE RELEASE DETECTION EQUIPMENT:	
<hr/>	
WHAT TO DO IF THERE IS A SPILL:	
<hr/>	
PHYSICAL ADDRESS OF FACILITY:	
STREET ADDRESS: _____	
MUNICIPALITY: _____	COUNTY: _____

This notice must be posted at the facility at all times
A Class C operator must be briefed annually on emergency procedures following initial training